



Development Services

Transportation Planning
305 Chestnut Street
PO Box 1810
Wilmington, NC 28402-1810

910 341-3258
910 341-7801 fax
www.wilmingtonnc.gov
Dial 711 TTY/Voice

DATE: 1.03.14
TO: ProTrak
FROM: Bill McDow
Transportation Planning

■ **WorkLive Reclamation [Plan Review# 3]**



TECHNICAL STANDARDS:

1. Increase proposed Driveway width from 14' to 16' to allow better egress and ingress of traffic to the site.
2. Revise General Notes# 18, to include "any broken driveway panels shall be replaced".
3. Revise General Notes# 33, to "Contact 910-341-5888 for more details."
4. Please let me know if you have any questions or if I can be of further assistance as this development moves through the review process.