



**Development Services**

Transportation Planning  
305 Chestnut Street  
PO Box 1810  
Wilmington, NC 28402-1810

910 341-3258  
910 341-7801 fax  
[www.wilmingtonnc.gov](http://www.wilmingtonnc.gov)  
Dial 711 TTY/Voice

**DATE:** 1.03.2014

**TO:** ProTrak

**FROM:** Bill McDow  
Transportation Planning

---

■ **Carolina Bay at Autumn Hall Phase 2 [Landscaping Plan review #2]**

**TECHNICAL STANDARDS:**

1. As previously stated, the Live Oak beside the electronic gate on Sheet L-100 is within the Sight Distance Triangle. Please reposition the tree from the area within the SDT.
2. As previously stated, reposition the Lacewell Elms, so they will be out of the 46'X46' Sight distance triangle for the intersection of Carolina Bay Drive and Old Garden Road.

Please let me know if you have any questions or if I can be of further assistance as this development moves through the review process.