



**Planning, Development
and Transportation**

Transportation Planning
305 Chestnut Street
PO Box 1810
Wilmington, NC 28402-1810

DATE: 01.04.2019
TO: ProTrak
FROM: Mitesh Baxi
Traffic Engineering

910 341-3258
910 341-7801 fax
www.wilmingtonnc.gov
Dial 711 TTY/Voice

■ **TROLLEY STATION [TRC Plan Review #3]**

TECHNICAL STANDARDS – DRIVEWAY ACCESS (Major Thoroughfares):

1. Site plan shows a concrete island at the driveway off Wrightsville Ave. `Right only` sign (R3-5R) must be installed at this island, in accordance with MUTCD to restrict the egress traffic from turning left into Wrightsville Ave.

TECHNICAL STANDARDS – ACCESS (driveway, sidewalk, and sight distance):

2. The driveways shall be installed in accordance with City standard detail(s) [[SD 3-03.3 & 3-03.4 CofWTSSM](#)]. Revise and show the dimension for the flares on the site plan. [[Sec.18-530 CofW LDC](#)]

Please let me know if you have any questions or if I can be of further assistance as this development moves through the review process.