



**Planning, Development
and Transportation**
Transportation Planning
305 Chestnut Street
PO Box 1810
Wilmington, NC 28402-1810

DATE: 01.05.2015

TO: ProTrak

FROM: Bill McDow
Transportation Planning

910 341-3258
910 341-7801 fax
www.wilmingtonnc.gov
Dial 711 TTY/Voice

■ **URBAN OASIS ON CASTLE STREET [Plan Review #4]**

1. Rear parking area is shown as a gravel parking lot. If this remains on the plan, it must meet the requirements for unpaved and paved parking lots with less than 25 parking spaces.
2. Sidewalk is not shown along front entrance to the 3 story building at the southern end of the site.
3. If the entrance to this building is flush with the pervious pavement, please note it on the site plan.
4. The pedestrian path / sidewalk connection to the public sidewalk on 6th street has disappeared.