



**Planning, Development
and Transportation**

Transportation Planning
305 Chestnut Street
PO Box 1810
Wilmington, NC 28402-1810

DATE: 01.09.2020

TO: ProTrak

FROM: Bill McDow
Transportation Planning

910 341-3258
910 341-7801 fax
www.wilmingtonnc.gov
Dial 711 TTY/Voice

■ **WRIGHTSVILLE LANDING [TRC Plan Review #3]**

TECHNICAL STANDARDS – ACCESS (driveway, sidewalk, and sight distance):

1. The proposed 5' Sidewalk along Wrightsville Avenue must meet the minimum 14'-18' clear recovery distances for this street. Please ensure the sidewalk is within a Pedestrian Access Easement and positioned a minimum 14'-18' from the Travelway/ edge of pavement.

TECHNICAL STANDARDS – Barrier Free Design:

2. No Further Comments.