



Development Services
Transportation Planning
305 Chestnut Street
PO Box 1810
Wilmington, NC 28402-1810

910 341-3258
910 341-7801 fax
www.wilmingtonnc.gov
Dial 711 TTY/Voice

DATE: 01.10. 2014

TO: ProTrak

FROM: Bill McDow
Transportation Planning

■ **THE CREEK AT WILLOWICK [plan review #4]**

TECHNICAL STANDARDS – ACCESS (driveway, sidewalk, sight distance):

1. Add Tactile Mats for each curb ramp on the site plan.
2. Ensure the slope of the curb ramps and sidewalks meets minimum requirements for Standard detail SD 08-15 [sidewalk] and perpendicular curb ramps SD 3-07. [[SD 8-15 and SD 3-07, CofW TSSM](#)]
3. No Further Comments.

Please let me know if you have any questions or if I can be of further assistance as this development moves through the review process.