



**Planning, Development  
and Transportation**

Transportation Planning  
305 Chestnut Street  
PO Box 1810  
Wilmington, NC 28402-1810

910 341-3258  
910 341-7801 fax  
[www.wilmingtonnc.gov](http://www.wilmingtonnc.gov)  
Dial 711 TTY/Voice

**DATE:** 1.10.2019  
**TO:** ProTrak  
**FROM:** Bill McDow  
Transportation Planning

---

■ **WILMINGTON MUNICIPAL GOLF COURSE [TRC Plan Review #4]**

**TECHNICAL STANDARDS – Barrier Free Design:**

1. The proposed Handicap Ramp on the Northside of the Clubhouse must have a landing/ turning area that meets ADA requirements. The present design and stairs on two sides of the landing area, appear to be encroaching on the landing area. Please provide dimensions, (on a detail or enlarged view) of this turning area.
2. The ramp down from the clubhouse to the Handicap Parking Spaces have a 5% descent that ends with stairs immediately adjacent to the landing/ turning area. Please consider enlarging this area or providing additional safe guards to prevent handicap persons attempting to stop in this area from continuing down the stairs at the end of this descent.
3. No Further Comments.