



**Planning, Development  
and Transportation**  
 Transportation Planning  
 305 Chestnut Street  
 PO Box 1810  
 Wilmington, NC 28402-1810

910 341-3258  
 910 341-7801 fax  
[www.wilmingtonnc.gov](http://www.wilmingtonnc.gov)  
 Dial 711 TTY/Voice

**DATE:** 01.17.2018  
**TO:** ProTrak  
**FROM:** Mitesh Baxi  
 Traffic Engineering

■ **VALVOLINE INSTANT OIL CHANGE [Plan Review #5]**

**NCDOT:**

It is the Applicant’s responsibility to coordinate directly with NCDOT to determine if any driveway permits/ revisions/ review processes are required. Contact NCDOT at 910. 251.2655. Please note additional comments may be forthcoming once coordination occurs.

**TECHNICAL STANDARDS – DRIVEWAY ACCESS (Major Thoroughfares):**

**Movement prohibition signs:**

‘No Left Turn’ sign (R3-2 – see the image below) must be installed at the Monolithic concrete island in accordance with MUTCD to restrict the egress traffic from turning left into Oleander Drive.



Please let me know if you have any questions or if I can be of further assistance as this development moves through the review process.