



**Planning, Development
and Transportation**

Transportation Planning
305 Chestnut Street
PO Box 1810
Wilmington, NC 28402-1810

910 341-3258
910 341-7801 fax
www.wilmingtonnc.gov
Dial 711 TTY/Voice

DATE: 01.22.2020

TO: ProTrak

FROM: Mitesh Baxi
Traffic Engineering

■ **TRU COLORS BREWERY [TRC Plan Review #3]**

TECHNICAL STANDARDS – PARKING:

1. The proposed pavement markings for on-street designated loading/unloading zone is not required and must not be installed. Please revise site plan accordingly.
2. Since the off-street parking spaces are 15.5' in depth adjacent curb for west side spaces must not be more than 4" in height, so it can work as wheel stops to accommodate 2.5' vehicle overhang.

A separate revision is not required and above changes can be done with final submission set. Please let me know if you have any questions.