



**Planning, Development
and Transportation**

Transportation Planning
305 Chestnut Street
PO Box 1810
Wilmington, NC 28402-1810

910 341-3258
910 341-7801 fax
www.wilmingtonnc.gov
Dial 711 TTY/Voice

DATE: 01.24.2019
TO: ProTrak
FROM: Mitesh Baxi
Traffic Engineering

■ **HOME 2 SUITES BY HILTON [TRC Plan Review #2]**

TECHNICAL STANDARDS – ACCESS (driveway, sidewalk, and sight distance):

1. The directional arrows shown at the north of Drop off/pick up zone (decorative paving) are in conflict. Please revise.

TECHNICAL STANDARDS – Barrier Free Design:

2. Show the accessible ramp(s), if required, for the accessible aisle for handicap spaces on the plan. Show the graphics for the detectable warning domes.

Please let me know if you have any questions or if I can be of further assistance as this development moves through the review process.