



**Planning, Development  
and Transportation**

Transportation Planning  
305 Chestnut Street  
PO Box 1810  
Wilmington, NC 28402-1810

910 341-3258  
910 341-7801 fax  
[www.wilmingtonnc.gov](http://www.wilmingtonnc.gov)  
Dial 711 TTY/Voice

**DATE:** 01.31.2017

**TO:** ProTrak

**FROM:** Bill McDow  
Transportation Planning

---

■ **BLYTHE RAOD SUBDIVISION [TRC Plan Review #2]**

**TECHNICAL STANDARDS – ACCESS (driveway, sidewalk, and sight distance):**

1. Thanks for showing the driveway notes.
2. Show Curb ramps at the street corner intersection. Connect the sidewalk to the curb ramps at Blythe Road and Canterbury and Canterbury and Live Oak Parkway.
3. The proposed Street Cross Section shows Type A curb on one side and Slope Curb on the other side of the street. Slope curb appears to be the existing curb type in this area.
4. No Further Comments.