



**Planning, Development
and Transportation**
Transportation Planning
305 Chestnut Street
PO Box 1810
Wilmington, NC 28402-1810

DATE: 02.01.2019

TO: ProTrak

FROM: Bill McDow
Transportation Planning

910 341-3258
910 341-7801 fax
www.wilmingtonnc.gov
Dial 711 TTY/Voice

■ **NHRMC EMERGENCY WELL HOUSE [TRC Plan Review #2] Landscape**

TECHNICAL STANDARDS – ACCESS (driveway, sidewalk, and sight distance):

1. The Landscape Plans show Bradford Pear Trees within the Sight Distance Triangles for the Well House Driveway. The plan must have a statement that states, "All proposed vegetation within sight triangles shall not interfere with clear visual sight lines from 30"-10'."
2. No Further Comments.