



Planning, Development and Transportation

Transportation Planning
305 Chestnut Street
PO Box 1810
Wilmington, NC 28402-1810

910 341-3258
910 341-7801 fax
www.wilmingtonnc.gov
Dial 711 TTY/Voice

DATE: 02.06.2019
TO: ProTrak
FROM: Mitesh Baxi
Traffic Engineering

■ **THE POINTE AT BARCLAY BUILDINGS 5&6 [TRC Plan Review]**

Initial Review Note

All comments are based on adopted policy documents, specific City of Wilmington Land Development Code (CofW LDC) and City of Wilmington Technical Standards and Specifications Manual (CofWTSSM) requirements in effect at the time of this review. These have been noted after the comment as appropriate for your ease in further research.

The City Engineer may administratively approve dimensional variance requests per LDC Sec. 18-348. If the Applicant feels further interpretation is in order, please contact Transportation Planning directly to discuss in additional detail. Please apply for all administrative variances in writing, an email is acceptable or this may be included on the plan set. Please see Sec. 18-348 of the Land Development Code for the information required to process a variance request.



BASE INFORMATION:

- Revise all sheets to accurately illustrate the existing conditions on and surrounding this parcel. Show all adjacent traffic signs, lane configurations, traffic control devices and pavement markings on the site inventory plan. Please refer to the Technical Standards and Specifications Manual (link is below) Ch. VII C.1.a.2. for specific information and distance requirements. Contact Traffic Engineering at 341-7888 if you need assistance locating these elements.
<https://www.wilmingtonnc.gov/home/showdocument?id=1910>

TECHNICAL STANDARDS – PARKING:

1. The minimum standard vehicle parking space is 18’ in length. Please dimension.
2. Please show all the traffic control devices and pavement marking showing the traffic flow around buildings 5&6.
3. Appropriate pavement markings and signage shall be installed for the loading area to restrict the parking.

TECHNICAL STANDARDS – Barrier Free Design:

4. Insert the typical handicap sign detail on the plan as per ADA and City standards. [Sheets A1 of 5 and A2 of 5, CofW Sign Specification]
<https://www.wilmingtonnc.gov/home/showdocument?id=3940>

MISCELLANEOUS:

- ❖ We will reserve comments on the parking lot, driveway geometry and other technical issues until a full construction drawing is submitted.

Please let me know if you have any questions or if I can be of further assistance as this development moves through the review process.