



**Planning, Development  
and Transportation**

Transportation Planning  
305 Chestnut Street  
PO Box 1810  
Wilmington, NC 28402-1810

910 341-3258  
910 341-7801 fax  
www.wilmingtonnc.gov  
Dial 711 TTY/Voice

**DATE:** 02.09.2018

**TO:** ProTrak

**FROM:** Mitesh Baxi  
Traffic Engineering

---

■ **CITY OF WILMINGTON POLICE FIRE & CITY TRAINING FACILITY [TRC Plan Review #3]**

**TECHNICAL STANDARDS - Parking**

1. Please label the areas for the landscape islands within the parking facility.

**TECHNICAL STANDARDS – Barrier Free Design:**

2. The handicap sign for the accessible parking spaces does not meet the standard requirements. Reference the typical handicap sign detail on the plan as per ADA and City standards. [[Sheets A1 of 5 and A2 of 5, CofW Sign Specification](#)]  
<https://www.wilmingtonnc.gov/home/showdocument?id=3940>

Please let me know if you have any questions or if I can be of further assistance as this development moves through the review process.