



**Planning, Development  
and Transportation**

Transportation Planning  
305 Chestnut Street  
PO Box 1810  
Wilmington, NC 28402-1810

910 341-3258  
910 341-7801 fax  
www.wilmingtonnc.gov  
Dial 711 TTY/Voice

**DATE:** 02.12.2018

**TO:** ProTrak

**FROM:** Mitesh Baxi  
Traffic Engineering

---

■ **WOODLANDS AT ECHO FARMS TRACT 3B PHASE 1 [Plan Review #2]**

**STREET LIGHTING:**

1. Minimum of 16 street lights are required for this sub-division as per the initial review comments. A layout submitted for review displays only 15 street lights. Please revise.

**GENERAL NOTES TO ADD TO THE PLAN:**

- A. If these units are sold at any point, the buyer must receive a subdivision street disclosure statement. Please note this on the site plan and advise the property owner of this requirement. [[Sec.18-378 \(e\) CofW LDC](#)]

Please let me know if you have any questions or if I can be of further assistance as this development moves through the review process.