



**Planning, Development
and Transportation**
Transportation Planning
305 Chestnut Street
PO Box 1810
Wilmington, NC 28402-1810

DATE: 02.15.2019

TO: ProTrak

FROM: Bill McDow
Transportation Planning

910 341-3258
910 341-7801 fax
www.wilmingtonnc.gov
Dial 711 TTY/Voice

■ **CFPUA PUMP STATION# 10 REPLACEMENT [TRC Plan Review #3]**

TECHNICAL STANDARDS – ACCESS (driveway, sidewalk, and sight distance):

1. Provide a sidewalk along the frontage of this site.
2. Provide a connection between the site and the public sidewalk.

Please let me know if you have any questions or if I can be of further assistance as this development moves through the review process.