



DATE: 02.26.2020

TO: ProTrak

FROM: Bill McDow Transportation Planning

■ 17TH STREET MIXED USE [TRC Plan Review #4]

TECHNICAL STANDARDS – DRIVEWAY ACCESS (Major Thoroughfares):

- 1. The planting plan on Sheet LP1.00 and LP1.10 show a light pole within the new right turn lane. Please revise these plan sheets.
- 2. No Further Comments.

Planning, Development and Transportation Transportation Planning

305 Chestnut Street PO Box 1810 Wilmington, NC 28402-1810

910 341-3258 910 341-7801 fax www.wilmingtonnc.gov Dial 711 TTY/Voice