



**Planning, Development
and Transportation**

Transportation Planning
305 Chestnut Street
PO Box 1810
Wilmington, NC 28402-1810

910 341-3258
910 341-7801 fax
www.wilmingtonnc.gov
Dial 711 TTY/Voice

DATE: 02.26.2020
TO: ProTrak
FROM: Mitesh Baxi
Traffic Engineering

17TH STREET MIXED USE [TRC PLAN REVIEW #4]

Recommendation:

A 'ONE WAY' sign is recommended for the right-out only driveway to restrict the traffic from entering this driveway. Although, a 'Do not enter' signage is proposed parallel to S 17th St, this could be an addition to ensure it is clearly visible and S 17th St traffic does not slowdown in anticipation of entering this driveway.

If used, 'ONE WAY' sign shall be placed at the corner of the driveway facing traffic passing the one-way driveway ([Section 2B.40 MUTCD](#)). If installed, signage must be outside the ROW.

Please let me know if you have any questions.