



**Planning, Development  
and Transportation**  
Transportation Planning  
305 Chestnut Street  
PO Box 1810  
Wilmington, NC 28402-1810

**DATE:** 03.04.2020

**TO:** ProTrak

**FROM:** Bill McDow  
Transportation Planning

910 341-3258  
910 341-7801 fax  
[www.wilmingtonnc.gov](http://www.wilmingtonnc.gov)  
Dial 711 TTY/Voice

---

■ **GARRIS ROAD BOAT STORAGE [TRC Plan Review #2]**

**BASE INFORMATION:**

1. The proposed sheet C-2.2 appears to be missing from this plan submission.

**TECHNICAL STANDARDS – PARKING:**

2. The Proposed Fire Route and Auto Turns for the Fire Truck was on Sheet C-2.2, however, this sheet was not shown in this plan submission.
3. Please submit sheet C-2.2 with a turning movement for the Fire Truck.

**TECHNICAL STANDARDS – Barrier Free Design:**

4. The proposed handicap parking space has bollards in the area of the Van Accessible Aisle. Please remove the bollards. Handicap Accessible spaces must be kept clear from obstructions, including objects that will prevent the van from deploying its lift mechanism.

Please let me know if you have any questions or if I can be of further assistance as this development moves through the review process.