



**Planning, Development
and Transportation**

Transportation Planning
305 Chestnut Street
PO Box 1810
Wilmington, NC 28402-1810

DATE: 03.08.2018

TO: ProTrak

FROM: Bill McDow
Transportation Planning

910 341-3258
910 341-7801 fax
www.wilmingtonnc.gov
Dial 711 TTY/Voice

■ **WOODLANDS AT ECHO FARMS TRACT 3B [TRC Plan Review]**

TRAFFIC IMPACT:

- ❖ Please provide an update on the status of the Woodland TIA (ECHO FARMS) for this project.
- ❖ Please contact Amy Kimes, PE, Amy.kimes@wilmingtonnc.gov, at (910)473-5130 to provide the status update.

TECHNICAL STANDARDS – NEW ROADS:

1. Some of the plan sheets are missing the label for Road L. Please label Road L on all plan sheets.
2. Asphalt pavement section detail on C4.2 shows 2" of asphalt. City standard detail requires 3" of asphalt. [[Standard Detail, SD 3.01 CofW TSSM](#)]

TECHNICAL STANDARDS – ACCESS (driveway, sidewalk, and sight distance):

3. Some of the intersections appear to be missing the pavement markings for crosswalks and Stop Bars. Please revise.

Please let me know if you have any questions or if I can be of further assistance as this development moves through the review process.