



Development Services

Transportation Planning
305 Chestnut Street
PO Box 1810
Wilmington, NC 28402-1810

910 341-3258
910 341-7801 fax
www.wilmingtonnc.gov
Dial 711 TTY/Voice

DATE: 03.10.2015

TO: ProTrak

FROM: Bill McDow
Transportation Planning

■ **SAWMILL POINT [Plan Review# 6]**



TECHNICAL STANDARDS – ACCESS (driveway, sidewalk, sight distance):

1. Increase minimum sidewalk width to 5' for proposed internal sidewalk that connects to the buildings in order to meet requirements for ADA and Technical Standards.
2. No Further Comments.