



**Planning, Development  
and Transportation**

Transportation Planning  
305 Chestnut Street  
PO Box 1810  
Wilmington, NC 28402-1810

910 341-3258  
910 341-7801 fax  
[www.wilmingtonnc.gov](http://www.wilmingtonnc.gov)  
Dial 711 TTY/Voice

**DATE:** 03.14.2019

**TO:** ProTrak

**FROM:** Mitesh Baxi  
Traffic Engineering

---

■ **HOME 2 SUITES BY HILTON [TRC Plan Review #3]**

**TECHNICAL STANDARDS – Barrier Free Design:**

1. Regardless of the ramps, detectable warning domes must be installed at the end of each accessible aisle/sidewalk before entering drive aisle/pavement surface. It provide a distinctive texture intended to alert handicap persons approaching vehicular areas [City/ADA standards]. Show the graphics of the domes at each accessible aisles.

Please let me know if you have any questions or if I can be of further assistance as this development moves through the review process.