



**Planning, Development
and Transportation**

Transportation Planning
305 Chestnut Street
PO Box 1810
Wilmington, NC 28402-1810

910 341-3258
910 341-7801 fax
www.wilmingtonnc.gov
Dial 711 TTY/Voice

DATE: 03.19.2018

TO: ProTrak

FROM: Mitesh Baxi
Traffic Engineering

■ **JENNS CONTRACTING [TRC Plan Review #3]**

TECHNICAL STANDARDS – ACCESS (driveway, sidewalk):

1. The existing driveway is not as per City standard [SD 3-03.3](#) & [3-03.4](#). The minimum two-lane driveway width is 23'. Please revise. [[7-9 CofW Tech Stds](#)].
2. If the preference is to utilize 19.2' driveway as a one-way, an appropriate traffic sign must be installed as per MUTCD standards. Show the location of the sign on the site plan.

Please let me know if you have any questions or if I can be of further assistance as this development moves through the review process.