



**Planning, Development  
and Transportation**

Transportation Planning  
305 Chestnut Street  
PO Box 1810  
Wilmington, NC 28402-1810

**DATE:** 03.19.2020

**TO:** ProTrak


**FROM:** Mitesh Baxi  
Traffic Engineering

910 341-3258  
910 341-7801 fax  
www.wilmingtonnc.gov  
Dial 711 TTY/Voice

**■ NORTH MARKET STORAGE EXPANSION [TRC Plan Review #3]**

**TECHNICAL STANDARDS:**

1. Revise the City's 20'x70' sight distance triangle at the driveway as per below image. [\[Sec.18-529\(c\) \(3\) CofW LDC\]](#) [\[Sec. 18-812 CofW LDC\]](#).



Please let me know if you have any questions.