



**Planning, Development
and Transportation**
Transportation Planning
305 Chestnut Street
PO Box 1810
Wilmington, NC 28402-1810

DATE: 03.21.14

TO: Justin Bishop, P.E.; Malpass Engineering
ProTrak

FROM: Bill McDow
Transportation Planning

910 341-3258
910 341-7801 fax
www.wilmingtonnc.gov
Dial 711 TTY/Voice

■ **EVERMORE APARTMENTS [Review OF Gates]**



TECHNICAL STANDARDS:

1. The median island appears to be too long for a vehicle to turn around between the island and the closed gate assembly.
2. Please submit a vehicle turning movement for the gate area to show that a standard vehicle or SUV and a delivery Van (FEDEX or UPS single unit Truck) will be able to turn in front of the gate and exit the site without having to back out onto Bonham Ave.
3. Add dimensions for the gate assembly and opening.

Please contact Transportation Planning, at 341-7819, if you need further clarification on any of the attached comments.