



**Planning, Development
and Transportation**

Transportation Planning
305 Chestnut Street
PO Box 1810
Wilmington, NC 28402-1810

910 341-3258
910 341-7801 fax
www.wilmingtonnc.gov
Dial 711 TTY/Voice

DATE: 03.21.2016
TO: ProTrak
FROM: Bill McDow
Transportation Planning

■ **THE POINTE AT BARCLAY COMMERCIAL PHASE 1 LANDSCAPE [Landscape Plan Review]**

TECHNICAL STANDARDS – ACCESS (driveway, sidewalk, and sight distance):

1. The approach view of the Stone Crop Dr. crosswalk appears to be partially blocked by the understory branches and anticipated spread of the Overcup Oaks and American Hornbeam trees. Please verify that the proposed Overcup Oaks and American Hornbeam trees will not block a vehicle's clear views of the Cross Walk on Stone Crop Dr. on Sheet L-1. at other Roundabouts on the plan.
2. No Further Comments.