



**Planning, Development
and Transportation**

Transportation Planning
305 Chestnut Street
PO Box 1810
Wilmington, NC 28402-1810

910 341-3258
910 341-7801 fax
www.wilmingtonnc.gov
Dial 711 TTY/Voice

DATE: 03.26.2018

TO: ProTrak

FROM: Bill McDow
Transportation Planning

■ **CAROLINAS COLLISION CENTER [TRC Plan Review #4]**

TECHNICAL STANDARDS – ACCESS (driveway, sidewalk, and sight distance):

1. The proposed sidewalk area across the driveway does not meet city technical standards. Provide a tactile mat and wheel chair ramp on both sides of the driveway.
2. The reduced one way drive aisle meets the standard for 60 degree parking.
3. The landscaping island at the end of the angled 60 degree parking does not appear to be a minimum of 216 SF. Please label the landscaping island.
4. The dimensions for the proposed dumpster pad are not labeled.
5. Please update the proposed notes to change "Skipper Funderburg" to Engineering.