



**Planning, Development  
and Transportation**

Transportation Planning  
305 Chestnut Street  
PO Box 1810  
Wilmington, NC 28402-1810

910 341-3258  
910 341-7801 fax  
[www.wilmingtonnc.gov](http://www.wilmingtonnc.gov)  
Dial 711 TTY/Voice

**DATE:** 13.29.2019

**TO:** ProTrak

**FROM:** Bill McDow  
Transportation Planning

---

■ **PEACE BAPTIST EXPANSION [TRC Plan Review #3]**

**TECHNICAL STANDARDS – ACCESS (driveway, sidewalk, and sight distance):**

1. Please show pavement markings for the 36.8' wide driveway. Pavement markings must be installed for driveways 36' or greater.
2. Please show the elevation of the driveway at 26', 52' and edge of pavement. If the slope is known, this can be substituted for the elevations.

**TECHNICAL STANDARDS – PARKING:**

3. The plans do not show a landscape plan. Please submit a separate plan or show required landscaping on the site plan.

Please let me know if you have any questions or if I can be of further assistance as this development moves through the review process.