

**DATE:** 03.30.2020

**TO:** ProTrak



**FROM:** Mitesh Baxi  
Traffic Engineering

910 341-3258  
910 341-7801 fax  
www.wilmingtonnc.gov  
Dial 711 TTY/Voice

■ **CAPE FEAR SOLAR SYSTEMS [Landscape plan\_Review1]**

**Sight distance:**

1. Show and apply the City's 20'x70' sight distance triangle at each driveway and the City's 46'x46' sight distance triangle at each street corner intersection on the landscaping plan. [[Sec.18-529\(c\) \(3\) CofW LDC](#)] [[Sec. 18-812 CofW LDC](#)].



2. **Sight distance triangle for any street intersections with said thoroughfares:**

S Front St is a major thoroughfare [[Chap VII \(C\) \(2\) \(a\) of CofW Tech Stds](#)]. The required triangular sight distance for any street intersections with said thoroughfares shall be provided in compliance with the AASHTO sight distance standards [[Sec.18-556 CofW LDC](#)]. Show AASHTO sight distance for the street corner of Wright St and Dawson St with S Front St.

Please let me know if you have any questions.