



DATE: 04.02.2020

TO: ProTrak


FROM: Mitesh Baxi
Traffic Engineering

910 341-3258
910 341-7801 fax
www.wilmingtonnc.gov
Dial 711 TTY/Voice

NORTH MARKET STORAGE EXPANSION [TRC Plan Review #4]

TECHNICAL STANDARDS:

Site plan shows proposed sidewalk in front of this property. An ADA ramp at the corner of street type driveway abutting the eastern and western boundary of the property are required and shall be installed as per City/NCDOT standards. This was missed to comment on initially, but it will be required. A separate revision will not be required and this change can be made with the final submittal. If these ADA ramps are to be constructed by others, please label accordingly.



Please let me know if you have any questions.