



**Planning, Development
and Transportation**

Transportation Planning
305 Chestnut Street
PO Box 1810
Wilmington, NC 28402-1810

DATE: 04.22.2019

TO: ProTrak

FROM: Bill McDow
Transportation Planning

910 341-3258
910 341-7801 fax
www.wilmingtonnc.gov
Dial 711 TTY/Voice

■ **WOODLANDS AT ECHO TRACT 3A [TRC Plan Review #6]**

TECHNICAL STANDARDS – NEW ROADS:

1. Please coordinate street names on Site plans and Landscape plans. The plans do not show the same street names for the section of Midvale Drive, near Building 1, and Chastain Drive, south of the roundabout at Building 12.

TECHNICAL STANDARDS – ACCESS (driveway, sidewalk, and sight distance):

2. The landscape plans show Street Trees located within the Sight Distance Triangles. Please ensure vegetation within the 20'X70' Sight Distance Triangles are maintained to provide clear visual sight lines from 30" to 10'.

Please let me know if you have any questions or if I can be of further assistance as this development moves through the review process.