



**Planning, Development  
and Transportation**

Transportation Planning  
305 Chestnut Street  
PO Box 1810  
Wilmington, NC 28402-1810

910 341-3258  
910 341-7801 fax  
[www.wilmingtonnc.gov](http://www.wilmingtonnc.gov)  
Dial 711 TTY/Voice

**DATE:** 04.03.2017

**TO:** ProTrak

**FROM:** Bill McDow  
Transportation Planning

---

■ **NHRMC EMPLOYEE PARKING DECK [TRC Plan Review #4]**

**TECHNICAL STANDARDS – ACCESS (driveway, sidewalk, and sight distance):**

1. The CFPUA backflow preventor is shown within the sight distance triangle for the Pharmacy Drive Exit.
2. Please show the height of the proposed RPZ Backflow Preventor and CFPUA Enclosure. Items in the SDT must not hinder clear visual sight distance from 30" to 10'.
3. Ensure ADA accessible path is shown on the site plans for the Employee Deck. The ADA Accessible path to the Elevators for the Pedestrian Bridge can be shown also.
4. No Further Comments.