



**Planning, Development
and Transportation**

Transportation Planning
305 Chestnut Street
PO Box 1810
Wilmington, NC 28402-1810

910 341-3258
910 341-7801 fax
www.wilmingtonnc.gov
Dial 711 TTY/Voice

DATE: 04.04.2018

TO: ProTrak

FROM: Mitesh Baxi
Traffic Engineering

■ **CAPE FEAR BOULEVARD APARTMENTS [TRC Plan Review #2]**

TECHNICAL STANDARDS – ACCESS (driveway, sidewalk, and sight distance):

TECHNICAL STANDARDS – PARKING:

1. Restricted or prohibited parking sign must be installed as per MUTCD, at the end of the proposed backing stub, to allow maneuvering of emergency vehicles and trash truck.

TECHNICAL STANDARDS – Barrier Free Design:

2. Show the typical handicap sign detail on the plan as per ADA and City standards. [[Sheets A1 of 5 and A2 of 5, CofW Sign Specification](#)]
<https://www.wilmingtonnc.gov/home/showdocument?id=3940>

Please let me know if you have any questions or if I can be of further assistance as this development moves through the review process.