



**Planning, Development
and Transportation**

Transportation Planning
305 Chestnut Street
PO Box 1810
Wilmington, NC 28402-1810

910 341-3258
910 341-7801 fax
www.wilmingtonnc.gov
Dial 711 TTY/Voice

DATE: 04.04.2019

TO: ProTrak

FROM: Mitesh Baxi
Traffic Engineering

■ **GREY COMMONS APARTMENTS [TRC Plan Review #5]**

TECHNICAL STANDARDS – PARKING:

- The reduction in drive aisle for the perpendicular parking to 20' is subject to variance from Engineering. [\[Page 7-19 Table 6 of CofW Tech Stds\]](#)

No other comments.