



**Planning, Development
and Transportation**
Transportation Planning
305 Chestnut Street
PO Box 1810
Wilmington, NC 28402-1810

DATE: 04.06.2016

TO: ProTrak

FROM: Bill McDow
Transportation Planning

910 341-3258
910 341-7801 fax
www.wilmingtonnc.gov
Dial 711 TTY/Voice

■ **ORIOLE DRIVE OFFICE [TRC Plan Review #3]**

TECHNICAL STANDARDS – PARKING:

1. As previously requested, the site is adjacent to UNCW and many bike facilities, therefore, the developer is asked to provide bicycle parking.

TECHNICAL STANDARDS – Barrier Free Design:

2. Please show the details of handicap ramp on the plan.
3. Placement of Van Accessible Plaque (R7-8P) with the Restricted Parking Sign (R7-8) does not meet MUTCD Standard.

MUTCD Standard: 08 Where parking spaces that are reserved for persons with disabilities are designated to accommodate wheelchair vans, a VAN ACCESSIBLE (R7-8P) plaque shall be mounted below the R7-8 sign.

Please let me know if you have any questions or if I can be of further assistance as this development moves through the review process.