



**Planning, Development
and Transportation**
Transportation Planning
305 Chestnut Street
PO Box 1810
Wilmington, NC 28402-1810

DATE: 04.08.2016

TO: ProTrak

FROM: Bill McDow
Transportation Planning

910 341-3258
910 341-7801 fax
www.wilmingtonnc.gov
Dial 711 TTY/Voice

■ **SEA SELL AUTO [TRC Plan Review# 2]**

TECHNICAL STANDARDS – PARKING:

1. Provide protection for the lawn near the bike racks and 5 employee parking spaces. This area is directly across from the Stormwater pond. Protection from vehicles is required around all required landscaped areas within vehicular areas.

TECHNICAL STANDARDS – Barrier Free Design:

2. Please show location of handicap signs and provide details on the plan.

GENERAL NOTES TO ADD TO THE PLAN:

- A. All parking stall markings and lane arrows within the parking areas shall be white.

MISCELLANEOUS:

- ❖ Permitting of business identification signage is a separate process. NCDOT/ City of Wilmington will not allow obstructions within the right of way.
- ❖ Contact Alina Dorofeeva at 341-7888, Alina.Dorofeeva@wilmingtonnc.gov, to discuss street lighting options.

Please let me know if you have any questions or if I can be of further assistance as this development moves through the review process.