



**Planning, Development
and Transportation**

Transportation Planning
305 Chestnut Street
PO Box 1810
Wilmington, NC 28402-1810

DATE: 04.14.2016

TO: ProTrak

FROM: Bill McDow
Transportation Planning

910 341-3258
910 341-7801 fax
www.wilmingtonnc.gov
Dial 711 TTY/Voice

■ **RIVERLIGHTS AGE QUALIFIED - PHASE 1 [Revised Plan Review]**

1. Verify the Sight Distance Triangles used on the plan. The Passerine Avenue and River Road Intersection should have a 46'X46' street style SDT, however, a 20'X70' SDT is shown on sheet CS-100.
2. Sheet 34, CS-501, appears to be missing the standard details that were included in the signature set of these plans, (10-1-15 set). The missing details appear to be SD 7-01 Curb Section, SD 3-07 Curb Ramp, SD 14-05 Monument Casting Detail, SD 15-01 Monument Casting and Base, and SD 3-10 Sidewalk.
3. Ensure the proposed changes do not result in areas where Street Lighting is not adequately installed/ spaced. Contact Alina Dorofeeva at (910) 341-7893 alina.dorofeeva@wilmingtonnc.gov to discuss street lighting type and spacing.
4. No Further Comments.