



**Planning, Development  
and Transportation**

Transportation Planning  
305 Chestnut Street  
PO Box 1810  
Wilmington, NC 28402-1810

910 341-3258  
910 341-7801 fax  
[www.wilmingtonnc.gov](http://www.wilmingtonnc.gov)  
Dial 711 TTY/Voice

**DATE:** 04.15.2019

**TO:** ProTrak

**FROM:** Mitesh Baxi  
Traffic Engineering

---

■ **ECHO FARMS PARK [TRC Plan Review #2]**

**TECHNICAL STANDARDS – ACCESS (driveway):**

- Site plan shows crosswalk pavement markings across the southern driveway. Sidewalk continues across the concrete driveway so the crosswalk pavement marking is not required and shall not be installed.

Please let me know if you have any questions or if I can be of further assistance as this development moves through the review process.