



DATE: 04.22.2019

TO: ProTrak

FROM: Bill McDow Transportation Planning

HOME 2 SUITES HOTEL [TRC Plan Review #5]

TECHNICAL STANDARDS – ACCESS (driveway, sidewalk, and sight distance):

- 1. The proposed sidewalk crossing at the driveway and along Old Eastwood Road is not located on the ROW. The proposed section of sidewalk appears to be on a proposed waterline. Please consider shifting the sidewalk to the ROW at the driveway crossing.
- 2. No Further Comments.

Planning, Development and Transportation Transportation Planning

305 Chestnut Street PO Box 1810 Wilmington, NC 28402-1810

910 341-3258 910 341-7801 fax www.wilmingtonnc.gov Dial 711 TTY/Voice