



**Planning, Development  
and Transportation**

Transportation Planning  
305 Chestnut Street  
PO Box 1810  
Wilmington, NC 28402-1810

910 341-3258  
910 341-7801 fax  
[www.wilmingtonnc.gov](http://www.wilmingtonnc.gov)  
Dial 711 TTY/Voice

**DATE:** 04.23.2019

**TO:** ProTrak

**FROM:** Mitesh Baxi  
Traffic Engineering

---

■ **FLOW ACURA [TRC Plan Review #2]**

**TECHNICAL STANDARDS – Barrier Free Design:**

1. The new 5' sidewalk connection with the crosswalk shall be in accordance with ADA. Show the ramp (if applicable) and detectable warning domes before entering crosswalk/pavement surface. [City/ADA standards].

You may revise this in the final submission for signage. A separate submission is not required. Please let me know if you have any questions or if I can be of further assistance.