



**Planning, Development
and Transportation**

Transportation Planning
305 Chestnut Street
PO Box 1810
Wilmington, NC 28402-1810

910 341-3258
910 341-7801 fax
www.wilmingtonnc.gov
Dial 711 TTY/Voice

DATE: 04.25.2018

TO: ProTrak

FROM: Mitesh Baxi
Traffic Engineering

■ **DOLLAR GENERAL-WILMINGTON-CAROLINA BEACH [TRC Plan Review #2]**

TECHNICAL STANDARDS – ACCESS (driveway, sidewalk, and sight distance):

1. A pavement marking plan is required for all driveways greater than 30' in width. [[page 7-9 CofWTSSM](#)]. Please provide one.

TECHNICAL STANDARDS – PARKING:

2. Add the number of bicycle spaces required and proposed, to the site data. [[Sec.18-528\(f\) CofW LDC](#)]

Please let me know if you have any questions or if I can be of further assistance as this development moves through the review process.