



**Planning, Development
and Transportation**

Transportation Planning
305 Chestnut Street
PO Box 1810
Wilmington, NC 28402-1810

910 341-3258
910 341-7801 fax
www.wilmingtonnc.gov
Dial 711 TTY/Voice

DATE: 04.30.2018
TO: ProTrak
FROM: Bill McDow
Transportation Planning.

■ **CAPE FEAR BOULEVARD APARTMENTS [TRC Plan Review #2]**

TECHNICAL STANDARDS – PARKING:

1. The proposed emergency vehicle turning area must have 20' clearance between the face of curb and the dumpster area. Please increase by at least 1'.
2. Please adjust the wheel stop positions. The parking spaces must have 15.5' of clearance and 2.5' of vehicle overhang.
3. No Further Comments.