



**Planning, Development
and Transportation**
Transportation Planning
305 Chestnut Street
PO Box 1810
Wilmington, NC 28402-1810

DATE: 05.04.2015

TO: ProTrak

FROM: Bill McDow
Transportation Planning

910 341-3258
910 341-7801 fax
www.wilmingtonnc.gov
Dial 711 TTY/Voice

■ **3819 PARK AVENUE [Plan Review #2]**

TECHNICAL STANDARDS – ACCESS (driveway, sidewalk, and sight distance):

1. Ensure that all proposed vegetation within sight triangles shall not interfere with clear visual sight lines from 30"-10'. Trim limbs on the existing 25" Oak and 28" Oak trees. [[Sec.18-566 CofW LDC](#)]
2. No Further Comments.