



**Planning, Development
and Transportation**
Transportation Planning
305 Chestnut Street
PO Box 1810
Wilmington, NC 28402-1810

DATE: 05.10.2017

TO: ProTrak

FROM: Bill McDow
Transportation Planning

910 341-3258
910 341-7801 fax
www.wilmingtonnc.gov
Dial 711 TTY/Voice

■ **NHRMC EMPLOYEE PARKING DECK [TRC Plan Review #6]**

TECHNICAL STANDARDS – ACCESS (driveway, sidewalk, and sight distance):

1. The proposed sidewalk will be located on an existing water service and fire service. Please show them on the site plan.
2. The new sidewalk connection appears to be either a curb cut or wheel chair ramp. Please clarify the connection type on the site plan.
3. Please show a city 20'X70' sight distance triangle for this driveway on Pharmacy Drive Exit.
4. Please show a detail for the proposed bus stop and shelter.
5. The site has created sidewalk connections on both sides of Pharmacy Drive (both parking lots). Please consider placing a wheel chair ramp adjacent to the bus stop, to facilitate pedestrian access on both sides of Pharmacy Drive.
6. The concrete island appears to be directly behind the dumpster. Please verify that a Trash Truck can service the dumpster and back out without striking the island. If a bollard is placed on the concrete island, please show it on the site plan.