

**Planning, Development
and Transportation**

Transportation Planning
305 Chestnut Street
PO Box 1810
Wilmington, NC
28402-1810

DATE: 05.16.2017

TO: ProTrak

FROM: Bill McDow
Transportation Planning

910 341-3258
910 341-7801 fax

■ **LIDL GROCERY STORE ARBOR COMMONS [TRC Plan Review #4]**



TECHNICAL STANDARDS – NEW ROADS:

1. Provide reflectors and pavement markings on the traffic splitter Islands for the Mini-roundabout.

TECHNICAL STANDARDS – ACCESS (driveway, sidewalk, and sight distance):

2. The sidewalks adjacent to the loading dock appear to be beside a depressed loading zone area. Please add Railings along the edge of the elevated sidewalk area per ADA Guidelines.
3. Provide standard details for the Asphalt Multi-Use Path being installed on the plan sheets.
4. No Further Comments.