



**Planning, Development
and Transportation**
Transportation Planning
305 Chestnut Street
PO Box 1810
Wilmington, NC 28402-1810

DATE: 05.16.2017

TO: ProTrak

FROM: Bill McDow
Transportation Planning

910 341-3258
910 341-7801 fax
www.wilmingtonnc.gov
Dial 711 TTY/Voice

■ **THE HOMEPLACE SUBDIVISION [TRC Plan Review #2]**

TECHNICAL STANDARDS:

1. As previously stated, label the Pedestrian walking trail and describe the material for this trail.
2. Label the street corner radius for the intersection of Casa Court and Beasley Road. Ensure street corner radius is at least R35' per City of Wilmington Technical Manual.
3. No Further Comments.