



- A. All pavement markings in public rights-of-way and for driveways are to be thermoplastic and meet City and/or NCDOT standards. [\[Detail SD-13 CofW Tech Stds\]](#)
- B. All signs and pavement markings in areas open to public traffic are to meet MUTCD (Manual on Uniform Traffic Control Devices) standards. [\[Detail SD 15-13 CofW Tech Stds\]](#)
- C. Install reflectors per City and NCDOT standards. Traffic Engineering must approve of pavement marking layout prior to actual striping.
- D. It shall be the responsibility of the subdivider to erect official street name signs at all intersections associated with the subdivision in accordance with the Technical Standards and Specifications Manual. The subdivider may acquire and erect official street name signs or may choose to contract with the city to install the street signs and the subdivider shall pay the cost of such installation. Contact Traffic Engineering at 341-7888 to discuss installation of traffic and street name signs. Proposed street names must be approved prior to installation of street name signs.
- E. Any broken or missing sidewalk panels and curbing will be replaced.
- F. A landscaping plan indicating the location of required street trees shall be submitted to the City of Wilmington Traffic Engineering Division and Parks and Recreation Department for review and approval prior to the recording of the final plat. [\[SD 15-14 CofW Tech Stds\]](#)
- G. Contact Traffic Engineering at 341-7888 forty-eight hours prior to any excavation in the right of way.

**MISCELLANEOUS:**

- ❖ Include appropriate City of Wilmington approval stamps prior to submitting final plans.
- ❖ Transportation Planning Staff reserves the right to review and comment on any additional plans submitted for this development.

Please let me know if you have any questions or if I can be of further assistance as this development moves through the review process.