



**Planning, Development
and Transportation**
Transportation Planning
305 Chestnut Street
PO Box 1810
Wilmington, NC 28402-1810

DATE: 05.31.2018

TO: ProTrak

FROM: Bill McDow
Transportation Planning

910 341-3258
910 341-7801 fax
www.wilmingtonnc.gov
Dial 711 TTY/Voice

■ **GLOW ACADEMY [TRC Plan Review #3]**

TECHNICAL STANDARDS – ACCESS and BARRIER FREE ACCESS:

1. The location of the proposed gates within the Screen walls does not allow enough exits for Emergency/ Evacuations from buildings, such as the Cafeteria, Kitchen, Media and Middle School areas. Please add more gates in these areas.
2. Show the location of the proposed gates for the screen walls on the Landscape Plans. Please ensure the gate locations do not conflict with planting beds and landscape areas.
3. No Further Comments.