

Engineering has reviewed the plans for the Carolina Bay at Autumn Hall project submitted April 14, 2016 and have the following comments:

1. Please submit an updated Stormwater Management Permit Application Form.
2. Please submit a \$500.00 Major Modification Development Review fee.
3. Since the proposed drop inlet rims have changed in elevation, please submit updated pipe calculations.
4. Please submit an updated inlet drainage area map(s) (see submittal documents from 10-4-2012).
5. Please submit an updated Master Stormwater Plan to Date for Autumn Hall.
6. Please submit a copy of the modified NCDEQ offsite stormwater permit upon receipt.

Please submit one complete set of plans, application and pipe calculations to Engineering for additional review. Please call or email if there are any questions. Thank you.