



**Planning, Development
and Transportation**
Transportation Planning
305 Chestnut Street
PO Box 1810
Wilmington, NC 28402-1810

DATE: 06.16.2019
TO: ProTrak
FROM: Bill McDow
Transportation Planning

910 341-3258
910 341-7801 fax
www.wilmingtonnc.gov
Dial 711 TTY/Voice

■ **MARKET PLAZA ATM PLAN [TRC Plan Review]**

BASE INFORMATION-

- ❖ Please correct the spelling of “Clearance Bar” on the Enlarged Plan view on sheet A2. The current spelling is “Cleranace Bar”.

TECHNICAL STANDARDS – BARRIER FREE ACCESS:

1. Please ensure the ATM meets minimum access requirements for Handicap guidelines, such as ATM height and distance from the curb.
2. The site is adjacent to the S. Kerr Avenue Sidewalk. Please install/ show the closest Curb Cut that will permit access from the Sidewalk and Bus Stop for persons in Wheel Chairs.
3. Show elevations and/ or slopes and cross slopes for the ADA Accessible Path to this ATM, from the public Sidewalk and Bus Stop.

TECHNICAL STANDARDS – PARKING:

4. The site plan appears to be changing the existing parking lot and two way access to Angled Parking and One-Way Access. Please change parking spaces to meet Standards for 60 degree parking on City Technical Standards and Specifications. [\[Chapter 7, Table 6, page 7-19\]](#)
5. Provide One-Way and Do-Not Enter Signs to show the one way access to the ATM.
6. Label the dimensions for the 60 degree angled parking. Show parking space dimensions and width of the one-way drive aisle. [\[Chapter 7, Table 6, page 7-19\]](#)
7. Please show the closest Bicycle Parking on the Market Plaza site.

Please let me know if you have any questions or if I can be of further assistance as this development moves through the review process.